

## Test Report

**Report No:** SHRL80027-1/2008

**Page:** 1 of 5

**Date:** Aug. 13, 2008

SHANGHAI KAKU ELECTRIC EQUIPMENT CORP.

The below samples were submitted by client and said to be:

Product Description : AXIAL COOLING FAN  
Model No : KA1725  
Quantity : 2pcs  
Sample Receiving Date : Aug. 8, 2008  
Testing Period : From Aug. 11, 2008 to Aug. 12, 2008  
Test Request : IP55  
Test Method : Refer to IEC60529-2001 and client's requirement.  
Test Result(s) : For further details, please refer to the following pages.

Signed for and on behalf of  
SGS-CSTC Ltd.



Michael Zhang  
E&E Reliability Lab



## Test Report

**Report No:** SHRL80027-1/2008

**Page:** 2 of 5

**Date:** Aug. 13, 2008

We have tested the submitted sample(s) as requested and the following results were obtained:

**Test Equipment:**

Name	Model
Dust Chamber	SC-6
Water Proof Tester	T041101-01
HIPOT Test	ZHZ8
Electrical Character Meter	PF140A
Digital Tachometer	HT-400

**Test Information:**

Test Sequence	Test Item
1	Operating Current Measurement
2	Power Consumption Measurement
3	Withstand Voltage Test
4	Rotate Speed Measurement
5	IP55
6	Operating Current Measurement
7	Power Consumption Measurement
8	Withstand Voltage Test
9	Rotate Speed Measurement

**Test Method:** Refer to IEC60529-2001 & client's requirement, Degree of protection provided by enclosures (IP code)

IP code	IP 55	Sample Serial No.
First characteristic numeral	Dust-Protected Test	SHRL80027-1 #1
Second characteristic numeral	Protected against the ingress of water jets	SHRL80027-1 #2

**Test condition:**

**Test A. Dust-Protected Test**

Test Dust: 2kg/m<sup>3</sup> chamber volume and be kept in suspension during the test

Test Duration: 8 hours

Remark: According to client's requirement, the sample was powered on when test.

**Test Result(s): Satisfied.**

No dust was found in the sample, the sample was still operating after the test.

## Test Report

**Report No: SHRL80027-1/2008**

**Page: 3 of 5**

**Date: Aug. 13, 2008**

**Test B. Protected against the ingress of water jets**

Water Jet Nozzle: Ø6.3mm  
 Water Flow: 12.5l/min ± 5%  
 Water Pressure: about 30KPa  
 Distance: 2.5m~3m  
 Test Duration: each 3minutes for front side and back side

Remark: According to client's requirement, the sample was powered on when test.

**Test Result(s): Satisfied.**

No water was found in the sample, the sample was still operating after the test.

**Test Data:**

1. Operating Current: Measure the Operating Current with 230V AC.

Serial No.	Test Data	
	Before Test	After Test
SHRL80027-1 #1	0.157A	0.156A
SHRL80027-1 #2	0.161A	0.161A

2. Power Consumption: Measure the Power Consumption with 220V AC.

Serial No.	Test Data	
	Before Test	After Test
SHRL80027-1 #1	30.67W	30.26W
SHRL80027-1 #2	31.40W	31.30W

3. Withstand Voltage Test: Apply 1500V AC between Power Terminals and Case for 1 minute, and the leakage current was no more than 0.5mA.

Neither a dielectric breakdown nor a flashover shall occur during the test.

Serial No.	Test Data	
	Before Test	After Test
SHRL80027-1 #1	0.16mA	0.16mA
SHRL80027-1 #2	0.16mA	0.16mA

4. Rotate Speed: Measure the Rotate Speed with 230V AC.

Serial No.	Test Data	
	Before Test	After Test
SHRL80027-1 #1	2700 rev.	2686 rev.
SHRL80027-1 #2	2706 rev.	2709 rev.

## Test Report

Report No: SHRL80027-1/2008

Page: 4 of 5

Date: Aug. 13, 2008

Photos:

SHRL80027-1 #1

Before Test



After Test



SHRL80027-1 #2

Before Test



## Test Report

Report No: SHRL80027-1/2008

Page: 5 of 5

Date: Aug. 13, 2008

Photos: (continue)



\*\*\* End of Report \*\*\*